

**ADDENDUM NO. 2  
TO  
CONTRACT DOCUMENTS AND SPECIFICATIONS  
FOR  
AGRILIFE EXTENSION  
BMP STUDY AREA, PARKING AND DETENTION POND**

TO: PROSPECTIVE BIDDERS AND PLAN HOLDERS

The Plans, Specifications, and Contract Documents shall be modified as required by the following items:

Item 2-1

Plans, Sheet C-102:

Walk Bridge Detail, remove the following note:

"YARD STUF, INC.  
12' STANDARD HIGH RAIL  
WALK BRIDGE"

With the following:

"EXTERIOR ACCENTS  
12' HIGH RAIL GARDEN BRIDGE  
(ITEM GB504)"

Item 2-2

Plans, Sheet C-900:

Porous Concrete Detail No. 2, remove the following note:

"CRUSHED AGGREGATE"

With the following:

"1-1/2" TO 2" COARSE AGGREGATE"

Item 2-3

Plans, Sheet C-900:

Grass Pavers Detail No. 207, remove the following note:

"CRUSHED ROCK"

With the following:

"1-1/2" TO 2" COARSE AGGREGATE"

Item 2-4

Plans, Sheet C-900:

Porous Asphalt Detail No. 209, remove the following note:

"BASE RESERVOIR  
"1-1/2" TO 2" AGGREGATE"

With the following:

"1-1/2" TO 2" COARSE AGGREGATE"

Item 2-5

Plans, Sheet C-900:

Permeable Interlocking Concrete Pavers Detail No. 210, remove the following note:

"BASE RESERVOIR  
"1-1/2" TO 2" AGGREGATE"


With the following:

"1-1/2" TO 2" COARSE AGGREGATE"

All items in conflict with this addendum are hereby deleted.

THIS ADDENDUM IS MADE PART OF THE SPECIFICATIONS AND CONTRACT DOCUMENTS, AND SHALL BE ACKNOWLEDGED ON THE PROPOSAL AND ON THE BID ENVELOPE.

ALAN PLUMMER ASSOCIATES, INC.



Daniel W. Applegate, P.E.  
February 22, 2012

